

Registered Business/Engineer details can be checked at www.gassaferegister.co.uk or calling 0800 408 5500



Reference number: **5190144** | Date: **14/02/2025** | Next Inspection Date: **14/02/2026**

536192

Contractor Details		Installation Address		Client Address	
Company name: JSM Plumbing and Heating Services Phone: 07535722299 Contractor name: Joe Martin Gas Safe License Number: 5390205	2a Winslow Drive Immingham Lincolnshire DN40 2BQ	New Waltham Community Hall & Pavilion St Clements Way, New Waltham Grimsby Lincolnshire DN36 4GU	New Waltham Community Hall & Pavilion St Clements Way, New Waltham Grimsby Lincolnshire DN36 4GU		

Appliances															
	Location	Type	Make	Model	Owned by	Appliance serviced?	Flue type	Inspected & tested	Combustion Analyser CO2 Reading						
									Ratio	Percentage	PPM	High			
1	Kitchen	Combi Boiler GENWAT1	Ideal	Logic max 35	Landlord	Yes	Room sealed (RS)	Yes	0.0006	8.8	34	0.0012	8.9	145	20.6
2															
3															
4															

Appliances				Details of any defects identified			
Heat input	Unit of measure	Safety device operation	Visual Condition of Flue	Flue performance	Appliance safe	Were any defects identified?	Was any remedial action taken?
1	kWh	Pass	Pass	N/A	Pass	No	No
2							
3							
4							

Gas Supply and Pipe Work						Declaration	
Emergency control valve accessible and operable						Additional comments / Work	
Gas tightness	Pass	Gas supply pipework	Pass	Equipotential bonding	Seen	Let-By	Appliances tested
	Pass	Pass	Pass	Pass	Pass	Pass	1
Safety Devices							
CO Alarm Test		N/A		Smoke Alarm Test		N/A	
Engineer name				Customer name			
Joe Martin				Joe Martin			
Signature				Signature			
							



Registered Business/Engineer details can be checked at www.gassaferegister.co.uk or calling 0800 408 5500

Reference number: 5190144

Date: 14/02/2025 | Next Inspection Date: 14/02/2026

536192

Contractor Details		Installation Address	Client Address
Company name: JSM Plumbing and Heating Services Phone: 07535722299 Contractor name: Joe Martin Gas Safe License Number: 5390205	2a Winslow Drive Immingham Lincolnshire DN40 2BQ	New Waltham Community Hall & Pavilion St Clements Way, New Waltham Grimsby Lincolnshire DN36 4GU	New Waltham Community Hall & Pavilion St Clements Way, New Waltham Grimsby Lincolnshire DN36 4GU

Details of any defects identified			
	Details of any defects identified	Remedial action taken	Labelled and warning notice issued?
1	None	None	No
2			
3			
4			